



**U. S. Department of Homeland Security**  
**United States Coast Guard**  
**Certificate of Approval**

Coast Guard Approval Number: 164.136/30/0

Expires: 16 May 2008

FIRE DOORS (IMO)

ALVEDOOR AB  
BLADINGEVAGEN 32  
SE-342 32 ALVESTA  
SWEDEN

"A-15 Single Leaf Type A-15M" hinged door tested and approved in accordance with IMO FTP Code Annex 1, Parts 1 & 3.

Approved for use as an integrated part of fire resisting divisions of class "A-15". Maximum door leaf size is 1035 x 2112 mm (width x height). Maximum window size is 254 x 254 mm or equivalent area. Hose port may be included. Single-point latch with 13 mm throw. Door frame to be bolted or welded to bulkhead per manufacturer's instructions. IMO FTP Code test methods: Res. A.799(19), Res. A.653(16), and Res. A.754(18).

Identifying Data: Danish Institute of Fire Technology (DIFT) File No.: PG10689, Serial No. 7706. Alvedoor Dwgs: D201303, C201359 (window), C201307 (hose port), B201319 (sill). letter dated 20 August 2001.

Follow-Up Program: DIFT

Factory Location: Alvedoor AB  
Bladingevagen 32  
S-342 32 Alvesta, Sweden

Supersedes certificate 164.136/30/0 dated 18 August 2001.

\*\*\* END \*\*\*

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 16<sup>th</sup> DAY OF  
MAY 2003, AT WASHINGTON D.C.

J. G. LANTZ

Chief, Lifesaving and Fire Safety Standards Division  
BY DIRECTION OF THE COMMANDANT, U.S.C.G.