



U.S. Department of Transportation
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 164.136/33/0

Expires: 29 April 2007

FIRE DOORS (IMO)

ALVEDOOR AB
BLADINGEVAGEN 32
SE-342 32 ALVESTA
SWEDEN

"A-60 Single Leaf - Type A-60" hinged door tested and approved in accordance with IMO FTP Code Annex 1, Parts 1 & 3.

Approved for use as an integrated part of fire resisting divisions of class "A-60". Maximum door leaf size is 1034 x 2112 mm (width x height). Maximum window is 390 x 390 mm clear size. Hose port may be included. Single-point latch with 13 mm throw. Door frame to be bolted or welded to bulkhead per manufacturer's instructions. IMO FTP Code test methods: Res. A.799(19), Res. A.653(16), Res. A.754(18).

Identifying Data: Danish Institute of Fire Technology DIFT File No.: PG10818, serial No. 8084. Alvedoor Dwgs: D201352A, C201350D (Window), C201341B (hose port), B100635B (sill). USCG letter dated 05 November 2001.

Follow-Up Program: DIFT

Only valid for fire doors manufactured at the following location:

Alvedoor AB
Bladingevagen 32
S-342 32 Alvesta
Sweden

Approval certificate 164.136/33/0 dated 5 November 2001 is superceded to reflect additional window material and change in frame bolt spacing. Alvedoor drawings C201350C and D201352 are replaced by C201350D and D201352A respectively.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 29th DAY OF
APRIL 2002, AT WASHINGTON D.C.

R. L. Markle
R. L. MARKLE

Chief, Lifesaving and Fire Safety Standards Division
BY DIRECTION OF THE COMMANDANT, U.S.C.G.