



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 164.136/29/0

Expires: 16 May 2008

FIRE DOORS (IMO)

ALVEDOOR AB
BLADINGEVAGEN 32
SE-342 32 ALVESTA
SWEDEN

"B-15 Single Leaf Type B-30M" hinged door tested and approved in accordance with IMO FTP Code Annex 1, Parts 1 & 3.

Approved for use as an integrated part of fire resisting divisions of class "B-15". Maximum door leaf size is 934 x 2114 mm (width x height). Single-point latch with 13 mm throw. Kick-out panel maximum size is 500 x 400 mm (width x height). Door may include Alvedoor ventilation grille. Door frame to be attached to bulkhead per manufacturer's instructions. IMO FTP Code test methods: Res. A.799(19), Res. A.653(16), and Res. A.754(18).

Identifying Data: Danish Institute of Fire Technology (DIFT) File No.: G10487, serial No.7180. Alvedoor Dwgs. D301110, D301116, D100345 (vent), B100634A (sill). USCG letter dated 20 August 2001.

Follow-Up Program: DIFT

Factory Location: Alvedoor AB
Bladingevagen 32
S-342 32 Alvesta, Sweden

Supersedes certificate 164.136/29/0 dated 18 August 2001.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 16th DAY OF
MAY 2003, AT WASHINGTON D.C.

J. G. LANTZ
Chief, Lifesaving and Fire Safety Standards Division
BY DIRECTION OF THE COMMANDANT, U.S.C.G.